

HOME FIRE SAFETY EQUIPMENT

Apartment Home Safety Kit, Red
2 L ABF + Kidde Smoke Detector

Residential bundle pairing a red 2 L ABF domestic liquid extinguisher rated 8A 55B 40F with a Kidde 2030-DSR optical smoke detector for flats and small homes that need one SKU for early warning and reachable fire cover.



- 2 L red ABF extinguisher plus Kidde 2030-DSR detector
- 8A 55B 40F on the liquid extinguisher
- Red metal basket wall hanger in the box
- Optical smoke detector to EN 14604:2005

SPECIFICATIONS

Manufacturer model	Zestaw Bezpieczne Mieszkanie (UGPN-2x ABF/M + Kidde 2030-DSR)	Electrical safety	Live equipment to 1000 V
Contents	UGPN-2x ABF/M (Domowa 2 red) 2 L liquid extinguisher, red metal basket wall hanger, Kidde 2030-DSR optical smoke detector	Dimensions	368 mm high, 110 mm cylinder diameter
Fire rating	8A 55B 40F	Gross weight	3.5 kg
Capacity	2 L	Colour	Red extinguisher and hanger; white Kidde detector
Extinguishing medium	ABF liquid	Mounting	Red metal basket wall hanger included with extinguisher; ceiling or wall mount hardware with detector
Standard	Supplementary domestic equipment (not EN 3-7; non-standard label, no CNBOP-PIB)	Warranty	5 years (extinguisher); 3 years (detector)
Detector standard	PN-EN 14604:2006 (EN 14604:2005), TÜV Rheinland certified	Manufacture	Extinguisher manufactured in Poland
Detection type	Optical smoke detector, replaceable 9V battery	Article number	NV-HSK-AP01R
Operating temperature	+5 °C to +60 °C		

ORDERING AND DELIVERY

HS CODE	INCOTERMS	CONFORMITY		
8424.10	EXW · FCA · DAP	CE	ISO 9001	EN 14604:2005

PRODUCT OVERVIEW

European-manufactured apartment home safety kit from OGNIОCHRON S.A. in Poland, trade name Zestaw Bezpieczne Mieszkanie, sized for flats and small homes where buyers want early smoke warning and a reachable extinguisher in one consignment. The bundle pairs a red UGPN-2x ABF/M (Domowa 2 red) 2 L liquid extinguisher rated 8A 55B 40F with a red metal basket wall hanger and a Kidde 2030-DSR optical smoke detector on a replaceable 9V battery. The extinguisher covers solids, flammable liquids, cooking fats and oils, and energised equipment to 1000 V from +5 °C to +60 °C. The detector is certified to PN-EN 14604:2006 (EN 14604:2005) by TÜV Rheinland. The extinguisher is supplementary domestic equipment: it does not carry EN 3-7 or CNBOP-PIB approval because of the non-standard label, and is intended as additional home fire safety equipment, not as the primary portable for a public building or commercial premises.

Values are the declared specifications for each article and are confirmed against the delivered batch on the order confirmation.

